



Castilleja del Arroyo Homeowners Association

Located at 1001 & 1009 Murrieta Blvd., Livermore CA 94550
(925) 290-7456 / castillejadelarroyo@gmail.com / castillejadelarroyo.com

Send correspondence to



c/o Neighborhood Association Management
PO Box 10968, Pleasanton CA 94588-0968
Phone: (925) 243-1797 x103 Fax: (925) 243-1798
nmitchell@neighborhoodam.com

Annual Fire Safety Equipment Inspection Unit Owner's Compliance Declaration

All Castilleja del Arroyo HOA units are required to be in compliance with Section 310.9.1 of the California Building Code, NFPA 10 Standard for Portable Fire Extinguishers, as well as all provisions and rules mandated by the Governing Documents of the Castilleja del Arroyo Homeowners Association related to these fire safety equipment inspections.

This document is your annual attestation that your unit has the required fire safety equipment installed and this equipment is fully functional. Note: This attestation is not required if the fire safety equipment in your unit has been inspected by the CDA HOA.

I am the owner of the Unit _____. My signature below signifies my declaration that I am in full compliance with both the general requirements above and the following specific requirements:

1. All detectors installed in my unit have been installed according to the manufacturer's instructions and generally accepted wiring and installation practices.
2. All smoke detectors installed in my unit appear on the California State Fire Marshal's approved list.
3. All Carbon Monoxide detectors installed in my unit meet the requirements of the UL 2034 Standard.
4. One approved smoke detector is installed and functioning in each room where sleeping occurs.
5. One approved smoke detector is installed and functioning in the hallway leading to the room(s) where sleeping occurs.
6. If I have a two-story unit, one additional approved smoke detector is installed and functioning in the central area of the first floor.
7. One approved carbon monoxide (CO) detector is installed and functioning in the hallway leading to the room(s) where sleeping occurs.
8. If I have a two-story unit, one additional approved carbon monoxide (CO) detector is installed and functioning in the central area of the first floor.
9. A UL-Rated minimum Class 1-A: 10-B: C fire extinguisher is installed on the first floor of my unit and I have confirmed the pressure gauge is in the green.
10. If I have a two-story unit, I have installed an additional UL-Rated minimum Class 1-A: 10-B: C fire extinguisher on the second floor of my unit and have confirmed the pressure gauge is in the green.
11. I have provided to the Castilleja del Arroyo HOA Board a separate video with audio for each piece of equipment required to be installed showing the device completely installed, tested and fully functional.

Signature

Print Name

Date Signed

(Rev. 8-21-22)